

BULETIN DE INCERCARI – ANALIZE/ TEST REPORT

Nr.92.965.336 / 10.07.2017

Denumire Proba / Name of the sample	Apa de piscina
Data prelevarii / Date of production	06.07.2017
Locul prelevarii/ Simple	Piscina Lazy River
Adresa prelevarii /Adress of the sample place	Str.Divertismentului,Nr.1,Chiajna
Cod Proba / Identity of the sample	92.965.336
Numele clientului / Name of the Client	SC PARK EXPERT SERVICE DTL SRL
Adresa Clientului / Address of the Client	Str.Divertismentului,Nr.1,Chiajna
Reprezentant ALMARO / Representative Transfer efectuat de:	Adriana MUNTEANU Ana-Maria GRIGORE
Cantitatea prelevata / quantity of the simple	<u>1,0 litru, de catre reprezentantul ALMARO MED conform comenzii interne din data de 06.07.2017</u>
Observatii / Observations	<u>Rezultatele se refera numai la probele incercate Perioada de efectuare a analizelor 06-10.07.2017</u>
Conditii de mediu:	Temperatura-22°C Umiditate-46%

INDICATORI MICROBIOLOGICI / MICROBIOLOGY TESTS

DENUMIREA INDICATORULUI / NAME OF TEST	METODA DE INCERCARE/ TEST METHODS	VALORI MAXIME ADMISE*/ ADMISSIBLE MAXIM VALUE *	VALOARE DETERMINATA/ DETERMINATED VALUE
Numar Colonii la 37°C 1ml / Colony count at 37°C	SR EN ISO 6222/ 2004	<200	0
Numar total de bacterii coliforme/100ml Total Number of Coliforms bacteria	SR EN ISO 9308-1/2004	<10	0
Escherichia coli/100ml Escherichia coli	SR EN ISO 9308-1/2004	0	0
Enterococi intestinali / 100ml Intestinals enterococcus	SR EN ISO7899-2/2002	0	0
Pseudomonas aeruginosa /100ml	SR EN ISO 16266/2008	0	0

* Valorile maxime admise sunt conforme Ordinul MS 119/2014.

Nota: 1) Reproducerea partiala/totala a buletinului de analiza este interzisa
2) Orice modificare a continutului fara stampila ALMARO, duce la anularea buletinului de analize