

INDICATORI FIZICO-CHIMICI/ PHYSICAL AND CHEMICAL TESTS

DENUMIREA INDICATORULUI / NAME OF TEST	METODA DE INCERCARE/ TEST METHODS	VALORI MAXIME ADMISE*/ ADMISSIBLE MAXIM VALUE*	LOQ	VALOARE DETERMINATA/ DETERMINATED VALUE
pH	SR ISO 10523/2012	7,2-8,2 unit.pH	-	7,6
Clor rezidual liber/ Free residual Chlorine	SR EN ISO 7393-1/2002	0,5-1,5 mg/l	-	0,880
Clor total	SR EN ISO 7393-1/2002	- mg/l	-	0,900

* Valorile maxime admise sunt conforme Ordinul MS 119/2014.

Analize efectuate de / Analyses done by

Chimist / Chemist

Gabriela STROIE/Sanda PARASCHIV

Semnatura / Signature

Biolog/ Biologist

Mihaela MEIROSU

Semnatura / Signature

Elaborat de / Made By
Reprezentant Vanzari

Ana-Maria GRIGORE

Semnatura / Signature

Verificat / Checked by

Manager laborator / Laboratory Manager

Claudiu VELICA

Semnatura / Signature

Nota: 1) Reproducerea partiala/totala a buletinului de analiza este interzisa
2) Orice modificare a continutului fara stampila ALMARO, duce la anularea buletinului de analize

Cod.FL-5.10-02
Editia 1/Rev1